

Specialty Tank, Inc. tests each tank thoroughly prior to shipping. Due to transportation and handling defects might occur, that did not show up at the time of factory testing. STW, Inc. along with most National and State Codes require testing at the job-site by an experienced installer, prior to **INSTALLATION/FILLING**.

STW, Inc. accepts no liability beyond repair or replacement of the tank for defects in workmanship or material. We assume no responsibility for contingent liability resulting from defects in these products.

Above Ground Single Wall Tanks should be pressure tested to 5psi maximum while all welds are tested with a soapy solution

Above Ground Double Wall Tanks must be tested in accordance with the Petroleum Equipment Institute recommended practice RP100 or RP200. Each tank is to be in strict accordance with NFPA 30, NFPA 30A, and/or NFPA 31.

Engineering and Installation Assistance can be provided by STW, Inc. @ 215-949-2939

Significant safety consideration and controls should be established **PRIOR** to undertaking physical activities associated with Above Ground Storage Tanks.

**DO NOT HANDLE OR INSTALL ANY TANK WITHOUT HAVING KNOWLEDGE AND EXPERIENCE IN PROCEDURES INVOLVED WITH PROPER AND SAFE INSTALLATION FOR ANY TANKS USED FOR STORAGE OF STABLE, FLAMMABLE AND CONBUSTABLE LIQUIDS.**

All STW tanks are labeled properly prior to shipping. If tank is received without proper labeling contact us **AT ONCE**, as we sell to distributors and are unaware as to what the distributor and/or end user does to the tanks, such as repainting them, so we have no control and take no responsibility over labeling once our tanks leave our possession, as well as piping activities.

**NOTE: IF YOU DON'T HAVE ANY KNOWLEDGE OF FILLING AND/OR INSTALLING PARTS, PUMPS OR EQUIPMENT IN ANY SINGLE AND/OR DOUBLE WALL TANK PURCHASED FROM STW, INC. YOU MUST CALL US AND ASK FOR TECHNICAL SUPPORT, PRIOR TO INSTALLATION.**